

# Entry Permit Holder Report

SafeWork SA

Application ID 19917959

Entry Permit Holder	
<b>Full Name:</b>	Alexander Capper/ Adrian Valente
<b>Permit Number:</b>	2401622/2302417
<b>Union Represented:</b>	CEPU SA
Worksite Entered	
<b>Business Name:</b>	50 Franklin
<b>Industry:</b>	Construction
<b>Address:</b>	50 Franklin St, Adelaide
<b>Date workplace entered:</b>	1/08/24

**I Alexander Capper/ Adrian Valente am of the opinion that the PCBU has contravened the WHS legislation relating to:**

	<b>Alleged Contravention</b>	<b>More information</b>	<b>Was the contravention rectified?</b>
PCBU Alleged Contravention 1	Not maintaining a safe work environment	Temporary wiring not installed as per AS3012 - Exit lights to be reoriented to ensure directing to egress path Failure to implement control measures for risk of fires - Hydrants/hosereels not installed - no fire extinguishers at required exits Failure to control risk of falling objects - open penetrations -no screens on penetrations to prevent objects being dropped through hand rails	No



		Failure to provide access/egress without risk to health and safety - egress path blocked by scaffold without redirecting workers - trip hazards in egress paths and stairwells	
--	--	--	--

