

Entry Permit Holder Report

SafeWork SA

Application ID 17895827

Entry Permit Holder	
Full Name:	Kelly Sara Bowey
Permit Number:	ET-22-05879
Union Represented:	Community and Public Sector Union - SPSF
Worksite Entered	
Business Name:	Port Pirie Regional Health Service
Industry:	Other
Address:	The Terrace & Alexander Street Port Pirie SOUTH AUSTRALIA 5540
Date workplace entered:	1/06/2023 12:00:00 AM

I Kelly Sara Bowey am of the opinion that the PCBU has contravened the WHS legislation relating to:		
Contravention	More information	Was the contravention rectified?
Not maintaining a safe work environment	Concerns with structural integrity of the ceilings on Ground and First floors, as well as excessive load bearing due to electrical cables. Risk of injury due to ceiling collapse, electrocution, failure of fire detection system, failure of medical air. Risk to workers and members of the public.	No
Not maintaining safe plant and structures	Contravention re structural integrity of ceilings on Ground and First floors, as well as excessive load bearing due to electrical cables. Ceilings observed to be warped and bowed in areas. Issue has been repeatedly reported, with PCBU that advised building contractors cannot certify integrity of structure, with an engineer required.	No