

# Entry Permit Holder Report

SafeWork SA

Application ID 19644223

| Entry Permit Holder     |                                 |
|-------------------------|---------------------------------|
| Full Name:              | Michael Jackson                 |
| Permit Number:          | ET-24-00735                     |
| Union Represented:      | CFMEU SA Branch                 |
| Worksite Entered        |                                 |
| Business Name:          | Shape - Blackburn House         |
| Industry:               | Construction                    |
| Address:                | Grenfell St, Adelaide, SA, 5000 |
| Date workplace entered: | 06/06/2024                      |

**I Michael Jackson am of the opinion that the PCBU has contravened the WHS legislation relating to:**

|                              | Alleged Contravention                     | More information  | Was the contravention rectified? |
|------------------------------|---|---|----------------------------------|
| PCBU Alleged Contravention 1 | Not maintaining a safe work environment   | PCBU failed to manage risk<br>PCBU failed to provide safe lighting - not hard-wired to ensure charging of battery back-up | Yes                              |
| PCBU Alleged Contravention 2 | Not maintaining safe systems of work      | PCBU failed to provide emergency procedures on site   | Yes                              |
| PCBU Alleged Contravention 3 | Not maintaining safe plant and structures | PCBU failed to ensure electrical testing and tagging was current<br>Tape over outlets on main power box                   | Yes                              |

