

Entry Permit Holder Report

SafeWork SA

Application ID 22203508

Entry Permit Holder	
Full Name:	Cody Hastings
Permit Number:	ET 2500877
Union Represented:	CFMEU CG Division
Worksite Entered	
Business Name:	Lot 403 - Jurkovic Group
Industry:	Construction
Address:	Lot 403 Hanson Road, Dry Creek, next to Acrow yard, currently the job is a lot of upright pre-cast panels.
Date workplace entered:	19/09/2025

I Cody Hastings am of the opinion that the PCBU has contravened the WHS legislation relating to:			
	Suspected Contravention	More information	Was the contravention rectified?
PCBU Alleged Contravention 1	Not maintaining a safe work environment	No site management present on-site upon arrival, or prior. No first aider information on-site, or any information relating to who is managing the job. No emergency management plan on-site. No supervision from PCBU on job. Prior to arrival on-site, an injured worker had to be treated off-site due to	No

		first aid kit being located in a locked lunch room, and no first aider information being available to sub-contractors.	
PCBU Alleged Contravention 2	Inadequate facilities or access to facilities	<p>Site had two portaloos on trailers. Neither had soap. One had no water in it.</p> <p>Lunchroom was too small for number of workers on-site. Lunch room did not have any available drinking water. Lunchroom bin was overflowing. Very poor housekeeping.</p>	No
PCBU Alleged Contravention 3	Not maintaining safe plant and structures	<p>Lunchroom was being powered by a generator, which had no pre-start paperwork or maintenance paperwork, and no fire extinguisher nearby.</p> <p>Outside of the lunchroom was a point for a fire extinguisher, however it was missing.</p>	No
PCBU Alleged Contravention 4	Hindering or obstructing the EPH to exercise a right while at the workplace	<p>A representative of the PCBU, Jurkovic Group, arrived on-site approximately 20 minutes after our arrival. They refused to accept our right of entry Section 117 paperwork, and refused to allow us to enter site, continually telling us to 'fuck off'.</p> <p>After some discussions the builder refused to address the issues, and instead decided to kick the trades off-site, threatening to have the trades sacked.</p> <p>Builder continually made comments downplaying what their role as PCBU entails, asking several times if we expected him to 'wipe the workers ass for them too'.</p>	No