

Entry Permit Holder Report

SafeWork SA

Application ID 19930836

Entry Permit Holder	
Full Name:	Alexander Capper, Adrian Valente, Daniel Ramm
Permit Number:	2401622, 2302406, 2403056
Union Represented:	CEPU SA
Worksite Entered	
Business Name:	50 Franklin
Industry:	Construction
Address:	50 Franklin St, Adelaide
Date workplace entered:	12/08/2024

I Alexander Capper, Adrian Valente, Daniel Ramm am of the opinion that the PCBU has contravened the WHS legislation relating to:

	Alleged Contravention	More information	Was the contravention rectified?
PCBU Alleged Contravention 1	Not maintaining a safe work environment	Crane cables not installed as per AS3012 requirements regarding mechanical protection.	No
PCBU Alleged Contravention 2	Not maintaining a safe work environment	Conduits installed over crane cables have been sliced down the length of the conduit, altering the structural integrity outside of manufacturers instructions and can no longer be relied upon as mechanical protection.	No
PCBU Alleged Contravention 3	Not maintaining a safe work environment	Cable powering concrete pump installed without mechanical protection.	No

PCBU Alleged Contravention 4	Not maintaining a safe work environment	Work platform over duct penetration installed on hand rails.	No
PCBU Alleged Contravention 5	Not maintaining a safe work environment	Piles of concrete dust being left on site	No
PCBU Alleged Contravention 6	Not maintaining safe plant and structures	Ratchet strap tied to hand rail post used to secure personell hoist prior to slab pour.	No
PCBU Alleged Contravention 7	Not maintaining a safe work environment	Fire extinguishers not installed correctly	No
PCBU Alleged Contravention 8	Not maintaining a safe work environment	Nurse calls only installed every third floor, hazardous construction work being undertaken on floors with no emergency notification system in place.	No