

Entry Permit Holder Report

SafeWork SA

Application ID 19984924

Entry Permit Holder	
Full Name:	Alexander Capper, Adrian Valente
Permit Number:	ET-24-01622, ET-23-02417
Union Represented:	CEPU SA
Worksite Entered	
Business Name:	50 Franklin St
Industry:	Construction
Address:	50 Franklin
Date workplace entered:	21/08/2024

I Alexander Capper, Adrian Valente am of the opinion that the PCBU has contravened the WHS legislation relating to:

	Alleged Contravention	More information	Was the contravention rectified?
PCBU Alleged Contravention 1	Not maintaining a safe work environment	THE PCBU has failed to ensure crane cables and concrete pump cables are installed in compliance with AS 3012 section 2.5.3 having regard to the mechanical protection requirements. AS 3012 requires cables be installed in mechanical protection as required where a risk assessment is not done. A risk assessment has not been done. Were a risk assessment done the cable requires mechanical protection based on the following situations;	No



		<ul style="list-style-type: none">- has been installed within 2.5m of the floor- within 150mm of scaffolding- within 150mm of unearthed metal structures being installed as part of the construction process. <p>Areas of the cable have been attempted to be protected using modified conduit. As the conduit has been modified outside of the manufacturers specifications it can no longer be relied on as mechanical protection unless it has been suitably tested under the requirements of AS 3013.</p> <p>The installation fails to meet the requirements of AS 3012 and must be isolated and rectified.</p>	
--	--	---	--

