

Entry Permit Holder Report

SafeWork SA

Application ID 21008363

Entry Permit Holder	
Full Name:	Christopher Matonti
Permit Number:	ET - 24 - 01207
Union Represented:	SDA
Worksite Entered	
Business Name:	Chemist Warehouse Port Adelaide
Industry:	Retail Trade
Address:	168/180 St Vincent St, Port Adelaide SA 5015
Date workplace entered:	12/02/2025

I Christopher Matonti am of the opinion that the PCBU has contravened the WHS legislation relating to:

	Alleged Contravention	More information	Was the contravention rectified?
PCBU Alleged Contravention 1	Not maintaining a safe work environment	AC has been broken and was reported as a concern as early as May 2024. No solution had been actioned. The site temperature was measured in various locations ranging from 28-36 degrees. There was little ventilation. Immediate controls were not working. Workers reported and were visibly showing signs of heat related illness: dizziness, exhaustion, nausea, heat rash, vomiting, disorientation, and stomach cramps. Workers were concerned with the effect of heat on the ability to	No



		<p>concentrate on important tasks (medicine dispensary) and had concerns about the appropriate temperature for the storage of medication. There was evident customer aggression due to heat; verbally abusive interaction occurred on site regarding the temperature. Workers visibly distressed/crying. Workers exercised their right to cease work due to immediate risk to health and safety. PCBU became verbally abusive and threatened repercussions for their actions.</p>	
--	--	---	--

