

Entry Permit Holder Report

SafeWork SA

Application ID 19980732

Entry Permit Holder	
Full Name:	Adrian Valente Alexander Capper Daniel Ramm
Permit Number:	ET-23-02417 ET-24-01622 ET-24-03056
Union Represented:	The Communications Electrical Energy Information Postal Plumbing and Allied Services Union of Australia
Worksite Entered	
Business Name:	50 Franklin Street Development - Kyren Group
Industry:	Construction
Address:	52-56 Franklin Street, Adelaide, SA
Date workplace entered:	12/08/2024

I Adrian Valente Alexander Capper Daniel Ramm am of the opinion that the PCBU has contravened the WHS legislation relating to:

	Alleged Contravention	More information	Was the contravention rectified?
PCBU Alleged Contravention 1	Not maintaining a safe work environment	Failure to provide mechanical protection to construction wiring in accordance with AS-3012. No Mechanical protection on Crane feed cable.	No
PCBU Alleged Contravention 2	Not maintaining a safe work environment	Nurse calls not installed adjacent to hazardous activities. Nurse calls are not positioned on every level.	No
PCBU Alleged Contravention 3	Unsafe use, handling and storage of plant, structures and substances	Failure to remove and suppress airborne contaminants. Concrete dust not sweated up and left lying on floors.	No

PCBU Alleged Contravention 4	Inadequate facilities or access to facilities	Failure to maintain facilities.	No
PCBU Alleged Contravention 5	Not maintaining safe systems of work	Failure to manage risks of falls and falling objects. Screens not installed to manufactures specifications.	No
PCBU Alleged Contravention 6	Not maintaining a safe work environment	Fire Extinguishers not installed to the standards.	No