

# Entry Permit Holder Report

SafeWork SA

Application ID 19957230

Entry Permit Holder	
<b>Full Name:</b>	Adrian Valente Alexander Capper
<b>Permit Number:</b>	ET-23-02417 ET-21-01614
<b>Union Represented:</b>	The Communications Electrical Energy Information Postal Plumbing and Allied Services Union of Australia
Worksite Entered	
<b>Business Name:</b>	Cullinan Apartments - IJ Projects
<b>Industry:</b>	
<b>Address:</b>	181 Waymouth street, Adelaide
<b>Date workplace entered:</b>	15/11/2023

## I Adrian Valente Alexander Capper am of the opinion that the PCBU has contravened the WHS legislation relating to:

	Alleged Contravention	More information	Was the contravention rectified?
PCBU Alleged Contravention 1	Not maintaining a safe work environment	Failure to maintain access/egress emergency lighting in accordance with AS-3012.	Yes
PCBU Alleged Contravention 2	Not maintaining a safe work environment	Failure to maintain mechanical protection on construction wiring in accordance with AS-3012.	Yes