

Entry Permit Holder Report

SafeWork SA

Application ID 24030612

Entry Permit Holder	
Full Name:	Troy McIntyre
Permit Number:	ET2404448
Union Represented:	CFMEU - Construction Division
Worksite Entered	
Business Name:	Newton Shopping Centre Development Site
Industry:	Construction
Address:	299 Montacute Rd, Newton, SA 5074
Date workplace entered:	11/08/2026

I Troy McIntyre am of the opinion that the PCBU has contravened the WHS legislation relating to:

	Suspected Contravention	More information	Was the contravention rectified?
PCBU Alleged Contravention 1	Not maintaining safe systems of work	I believe the PCBU contravened the WHS Act Sect 19 Primary duty of care. A person conducting a business or undertaking must ensure, so far as is reasonably practicable, maintain a work environment without a risk to health and safety, maintain structures, and maintain safe systems of work. By instructing workers to enter an area under a concrete pour where props had bent during the pour, to put more props in so they could continue with the pour.	No

		Exposing the workers to an imminent risk to their health and safety in case of a collapse.	
PCBU Alleged Contravention 2	Not maintaining a safe work environment	Regulation 40 of the WHS Regulations. Duty in relation to general workplace facilities, A person conducting a business or undertaking at a workplace must ensure, so far as is reasonably practicable, the workplace is maintained so as to allow, for persons to enter and exit and to move about without risk to health and safety, both under normal working conditions and in an emergency, floors and other surfaces are maintained to allow work to be carried out without risk to health and safety, lighting enables each worker to carry out work without risk to health and safety and persons to move within the workplace without risk to health and safety and safe evacuation in an emergency. Access and egress ways under water, only 1 access point to work area, No emergency lighting or adequate lighting in work area.	No