

Entry Permit Holder Report

SafeWork SA

Application ID 23850517

Entry Permit Holder	
Full Name:	Cody Hastings
Permit Number:	ET2500877
Union Represented:	CFMEU Construction General
Worksite Entered	
Business Name:	Shannon Place Apartments, Hindmarsh Construction
Industry:	Construction
Address:	Shannon Place, Adelaide, 5000
Date workplace entered:	22/07/2026

I Cody Hastings am of the opinion that the PCBU has contravened the WHS legislation relating to:

	Suspected Contravention	More information	Was the contravention rectified?
PCBU Alleged Contravention 1	Not maintaining a safe work environment	Workplace had significant build up of silica dust throughout multiple levels of the jobsite.	No
PCBU Alleged Contravention 2	Not maintaining a safe work environment	Some levels did not have adequate stretcher access and egress.	No
PCBU Alleged Contravention 3	Not maintaining a safe work environment	Site did not have adequate protection of dropped objects in multiple areas, ie missing kickers, and gaps between scaffold decking components.	No

PCBU Alleged Contravention 4	Not maintaining a safe work environment	Power board was not adequately fixed to the floor, resulting in noncompliant powerboard.	No
PCBU Alleged Contravention 5	Not maintaining safe systems of work	Failure to maintain safe systems of work. Scaffolders had failed to setup and maintain adequate exclusion zones.	No
PCBU Alleged Contravention 6	Lack of information, training, instruction or supervision	Injured worker was taken to a medical facility after receiving a blow to the head, as opposed to calling an ambulance, which should have happened.	No
PCBU Alleged Contravention 7	Not maintaining safe systems of work	Worker dropped a ledger from approx 3-4m high which landed on a workers head, resulting in them being injured and hospitalised. Worker had failed to establish a clear exclusion zone below where they were working, and had failed to take adequate duty of care for other workers onsite, by not taking actions to minimise risk of dropped objects	No