

Entry Permit Holder Report

Application ID: 24274141

Entry Permit Holder	
Full Name:	Troy Leigh McIntyre
Permit Number:	ET2404448
Union Represented:	CFMEU - Construction Division

Worksite Entered	
Business Name:	Endeavour College Site
Industry:	Construction
Address:	Mawson Lakes Blvd, Mawson Lakes, SA 5095
Date workplace entered:	04/09/2026

I Troy Leigh McIntyre am of the opinion that the PCBU has contravened the WHS legislation relating to:

	Suspected Contravention	Summary of suspected contravention, discussions on rectification, and agreed actions with timeframes	Was the contravention rectified?
PCBU Alleged Contravention 1	Not maintaining a safe work environment	WHS Act 2012 Sect 17 Management of Risks. Sect 19 Primary Duty of Care. WHS Regulation 2012 Reg 529C Duty for processing of CSS to be controlled. Reg 40 Duty in relation to general workplace facilities. Failure by the PCBU to have any control measures in place to manage silica exposure to the workers. Silica dust was prevalent all over the job, evidence of dry	No

		sweeping, large amounts of silica dust left in piles. First Aid facilities unhygienic and poorly maintained, being used as lunch room and office, no privacy screens, first aid kit open with items left lying around, bed sheet was filthy and not desposable, no running hot water. Inadequate lighting throughout the site, no runningman signs, no clear access or egress, no delineated walkways.	
PCBU Alleged Contravention 2	Inadequate facilities or access to facilities	COP Managing Work Environment And Facilities 3.1 Access to facilities No access to toilets from inside site, workers have to go out site entrance gate onto public footpath then re enter site through delivery gate to access toilets. 3.3 Toilets Inadequate number of toilets, only 3 usable toilets pans onsite, portable toilet on level1 has broken lock and handle. 3.5 Eating Facilities Lunchrooms only seat 40 workers, there are minimum 65-70 workers onsite.	No

Summary of matters that remain unresolved: